



1099 Thompson Road, SE · Hartselle, AL 35640 · phone 256.773.2522

CERTIFICATE OF COMPLIANCE

January 2, 2014

To Whom It May Concern:

Cerro Wire LLC certifies that its XHHW-2 is manufactured and tested in the USA in a manner that assures compliance with the following specifications.

- UL 44 – File No. E125474
- CSA Master Contract 251402
- Rated RW90 per Canadian Standards
- Passes CSA's cold impact test at -40°C
- Cross – linked Polyethylene Insulation
- UL rated Sunlight Resistant 8 AWG and larger in all colors
- CSA rated Sunlight Resistant in black only
- For use in wet or dry locations at temperatures up to 90°C
- 1/0 and larger rated for use in Cable Trays
- ASTM – B3
- ASTM – B8
- ASTM – B787
- Federal Specification A-A-59544
- National Electric Code
- NEMA WC70/ICEA S-95-658-1999
- RoHS compliant

Sincerely,

A handwritten signature in black ink that reads "Richard C. Bennett".

Richard C. Bennett
Director of Quality

