



1099 Thompson Road, SE · Hartselle, AL 35640 · phone 256.773.2522

## CERTIFICATE OF COMPLIANCE

August 15, 2016

To Whom It May Concern:

Cerro Wire LLC certifies that its THHN/THWN-2 is manufactured and tested in the USA in a manner that assures compliance with the following specifications.

- ANSI/UL 83 (file no. E15119)
- ANSI/UL 1063 (19, 37, and 61 strand) (file no. E85964)
- Type TWN75 complies with Canadian Standard C22.2 No. 75. Type T90 Nylon complies with Canadian Standard C22.2 No. 75.
- NEMA WC70/ICEA S-95-658
- Federal Specification A-A-59544
- ASTM B3, B8, B787
- National Electric Code, NFPA 70
- 14 AWG through 1 AWG are rated VW-1
- All sizes (both solid and stranded) 14 AWG and larger are rated THWN-2
- Sizes 8 AWG through 1 AWG in black are rated sunlight resistant
- Sizes 1/0 and larger are rated sunlight resistant, for cable tray use
- RoHS compliant

Sincerely,

A handwritten signature in black ink, appearing to read "Kevin L. Dalrymple".

Kevin L. Dalrymple  
Director of Engineering and Quality



A Marmon/Berkshire Hathaway Company